



THE CIRCUIT IS SHOWN IN THE FOLLOWING CONDITIONS:  
 - CIRCUIT BREAKER OPEN  
 - RELEASES NOT TRIPPED  
 CONTACT SY (:95 & :98) CLOSES ON BREAKER TRIP.  
 CONTACT K51/Y01 (:4 & :1) CLOSES ON OVERCURRENT TRIP ONLY.  
 CONTACT OPENS WHEN BREAKER IS MOTORED OPEN.  
 NOTE: THIS CONTACT IS ONLY 24V D.C. RATED.

C	REMOVED C91 & C92 WIRES AND MADE C90 AS COMMON RETURN	27057	A.K.	05/04/07
B	REFERENCE TO S3 MCCB REMOVED	20923	G.C.T.	30/10/02
A	FIRST ISSUE	-	-	-
D	ISSUE DESCRIPTION	EGR/DGR	BY	DATE

- CUSTOMER POWER CONNECTION
- ⑪ A.C. CONNECTOR FROM ALTERNATOR
- ◀ BREAKER BOX TERMINAL

UNB/E/A3/01	1	2	3	4	5	6
-------------	---	---	---	---	---	---

THIS DRAWING IS COPYRIGHTED AND MAY BE COPIED ONLY FOR THE PURPOSES OF MAINTAINING THE PURCHASED EQUIPMENT BY THE PURCHASER		DRN. BY	G. THOMPSON	DATE	16/01/02	APPD. BY	<i>Jaune Hana</i>	DATE	24/04/2007	SHEET SIZE	A4	ORIGINAL SCALE	N.T.S.	DRAWING NO.	D35226	ISSUE	C
TITLE AC SECTION C/W MOT. BREAKER (S5) (OPTIONALISED)										ABB SACE S5 MOTORISED MCCB (DIRECT ACTION VERSION)		4-POLE BREAKER OPTIONAL (SEE NOTE REF.A01)					